



	12/10/2023	
	Roof access	



- Right of Access Permit is only for visual inspection and a different permit is required before commencing any work on the roof.
- Parapets are not a fall arrest system unless part of a submitted SWMS.
- Harness and dual latch system to be utilised when climbing roof ladders.

There is internal access to plant platforms via the first floor on the southern side of corridor next to room 132. A locked hatch (Roof access key) leads into the attic roof space, and a fixed ladder leads to a hatch and onto the roof.

The plant platform can be reached by fixed vertical ladder from the ground floor (stained glass) light well. Access to the light well is from corridor G01F.

North side of roof can be accessed via level 8 of Hughes Building (through window) across Kenneth Willis building roof walkway.



Likely	There is an expectation that an event/incident but not certain to occur.	Major	Injury requiring extensive medical treatment, hospitalisation, or activities could result in a Notifiable occurrence.
Slight	This expectation lies somewhere in the midpoint between "could" and "improbable"	Moderate	Injury requires formal medical treatment (hospital outpatient/doctors visit etc), activities could result in an Improvement Notice.
Unlikely	There is an expectation that an event/incident is doubtful or to occur	Minor	Injury requires first aid
Rare	there is no expectation that the event/incident will occur	Negligible	Injury requires minor first aid (e.g. band aid), or result in short term discomfort (e.g. bruise, headache, muscular aches, etc)
